




# Michael James Industries, Inc.

Heating, Ventilation and Air Conditioning  
Service • Design • Installation

November 14, 2011

Michael James Industries, Inc. has conducted a test of the Elima-Draft supply filtered register cover to determine if there is a restriction in airflow when installed. The test was performed on a standard residential ceiling register with the Elima-Draft supply filtered cover both on and off. Airflow tests were measured with an Alnor Balometer electronic capture hood. The results concluded that there was a slight increase in velocity with no significant decrease in airflow.

Sincerely,



Michael Herman, LEED AP, CBCP  
Vice President

MH:dl

*Servicing the industry with over 25 years of experience*